Chapter 19 Problem 37 †

Given

 $Oil - 1.0 \ kWh/gal$ Oil - \$1.75/gal $Electricity - \$0.165 \ /kWh$

Solution

What COP is needed for a heat pump to replace a fuel oil heating system.

First calculate how much energy you get per dollar for the two systems. For the electricity you get

$$energy_{electrity} = \$1.00 \left(\frac{1 \ kWh}{\$0.165} \right) = 6.06 \ kWh$$

For the fuel oil you get

$$energy_{oil} = \$1.00 \left(\frac{1 \ gal}{\$1.75}\right) \left(\frac{30 \ kWh}{1 \ gal}\right) = 17.14 \ kWh$$

Now the COP for a fuel pump is

$$COP = \frac{Q_h}{W}$$

If a dollar's worth of electricity does work on the heat pump and it is desired to have the same amount of heat generated as burning the fuel oil, then

$$COP = \frac{17.17 \ kWh}{6.06 \ kWh} = 2.83$$

This is the break even point. You would want to have a higher COP in order to recover the cost of installing the heat pump.

[†]Problem from Essential University Physics, Wolfson